

March 18, 2008

LAKE SHORE BURIAL VAULT CO., INC.
HUBERT MCQUESTION
12780 LISBON ROAD
BROOKFIELD WI 53005

DELTA ENVIRONMENTAL PRODUCTS, INC.
MIKE CATANZARO

PO BOX 969
DENHAM SPRINGS LA 70727

Re: Description: SEWAGE TREATMENT SYSTEMS, AERATED (also see SEWAGE TREATMENT APPARATUS)
Manufacturer: DELTA ENVIRONMENTAL PRODUCTS, INC.
Product Name: WHITEWATER AEROBIC TREATMENT UNIT
Model Number(s): DF-50-CA (500 GPD)
Product File No: 20080161

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of March 2010.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The maximum daily wastewater flow, which may discharge through this product, is 500 gallons per day.
- When this product is installed with the optional POLYLOK effluent filter(s) model PL-122, this product is recognized to not discharge any solid or suspended solid exceeding 1/8 inch in diameter.
- When this product is installed with the "UV The Disinfector" disinfection device and receives wastewater from dwellings and the flow through the UV disinfection does not exceed 6 gallons per minute, it will produce an effluent quality with a maximum monthly average value for BOD5 of less than or equal to 30 mg/L, TSS of less than or equal to 30 mg/L TSS and F.O.G. of less than 30 mg/L, and fecal coliform of less than or equal to 10,000 cfu/100ml.
- This product may be installed with PolyLok effluent filter model PL-122, and/or the "UV The Disinfector" disinfection device in accordance with the manufacturer installation instructions.

This approval supersedes the approval issued on 3/24/2005 under product file number 20050161. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050161.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov